



PRODUCT CONFORMITY COMMITMENT

1 - MANUFACTURER

Company : SLYCMA
Address : 235 rue du Général de Gaulle
69530 BRIGNAIS
Email : slycma@slycma.com

SIRET number : 972 509 210 00076
APE Code: 2822 Z
Telephone : + 33 0478 868 100

2 - CONCERNED PRODUCT RANGE

Type : **One panel swinging door**

Opening : **Semi-automatic**

Trade name : **LYNEA**

Panel characteristics : **Without vision panel**
Clear opening from 500 to 1300 mm

1. Tests, trials and compliance analysis (NF EN 81- 20 / 50)	Compliant
2. Compliance with the requirements of Directive 2014/33/UE : Locks GENALOCK UH, KRONENBERG, PRUDHOMME	Compliant
3. Fire resistance tests (NF EN 81-58 - Version May 2004) following range report number 11-A-045	E120 - EW 60
4. Installation in existing buildings (NF EN 81-21)	Compliant
5. Compliance with accessibility requirements (NF EN 81-70)	Compliant
6. Compliance analysis for anti-vandal applications (NF EN 81-71) • Category 1 : Resistance tests following ch 5.3.1 • Category 2 : Answers to ch 5.3.2 and to annex C	Compliant
7. Internal test of behavior in case of horizontal load, Vertical and dynamic on the open opening, in case of violent opening, in case of violent closure or annoyed.	Compliant

3 - SIGNATURE

First and last name : **Salvador JARA**
Function : **General Manager**

Signature :