



PRODUCT CONFORMITY COMMITMENT

1 - MANUFACTURER

Company : SLYCMA
Address : 235 rue du Général de Gaulle
69530 BRIGNAIS
Email : slycma@slycma.com

SIRET number : 972 509 210 00076
APE Code: 2822 Z
Telephone : + 33 0478 868 100

2 - CONCERNED PRODUCT RANGE

Type : **ARTICULATED HINGED SLIDING LANDING DOOR** Number of panels : **Multiple**
Trade name : **PAC 81 - PAC 81 «S»** Opening : **Lateral**

Dimensions : **Manual articulated sliding door from 700 to 2600 mm**
Simultaneous driving articulated sliding door from 700 to 2600 mm
Automatic articulated sliding door from 700 to 2600 mm

1. Tests, trials and compliance analysis (NF EN 81- 20 / 50)	Compliant
2. Compliance with the requirements of Directive 2014/33/UE : Locks GENALOCK UH, KRONENBERG, PRUDHOMME	Compliant
3. Fire resistance tests (NF EN 81-58 - Version May 2004) following range report number 11-A-169 for manual and simultaneous driving executions with GENALOCK UH locks	E120 - EW60
4. Installation in existing buildings (NF EN 81-21)	Compliant
5. Compliance with accessibility requirements (NF EN 81-70)	Compliant

3 - SIGNATURE

First and last name : **Salvador JARA**
Function : **General Manager**

Signature :