# PRODUCT CONFORMITY COMMITMENT

## 1 - MANUFACTURER

**Company :** SLYCMA
**Address :** 235 rue du Général de Gaulle
69530 BRIGNAIS
**Email** : slycma@slycma.com

**SIRET Number:** 972 509 210 00076
**APE Code:** 2822 Z

**Telephone :** + 33 (0)478 868 100

## 2 - CONCERNED PRODUCT RANGE

Type : **AUTOMATIC LANDING DOOR**
Trade name : **SD20**

Number of panels : **2**
Opening : **Lateral and central**

Dimensions : **2 panels side opening 700 to 1300 mm / CH 2000 to 2300 mm**
**2 panels central opening 700 to 1300 mm / CH 2000 to 2300 mm**

| | |
|---|---|
| 1. Tests, trials and compliance analysis (NF EN 81- 20 / 50) | Compliant |
| 2. Compliance with the requirements of Directive 2014/33/UE : SD20-1 lock system | Compliant |
| 3. Fire resistance tests (NF EN 81-58 - Version May 2004) following range report number EFR-17-001130 | E120 - EW 60<br>OC<br>E120 - EW 20<br>OL<br>in sheet metal version /<br>in st. steel cladded version |
| 4. Compliance with accessibility requirements (NF EN 81-70) | Compliant |
| 5. Compliance analysis for vandal-resistant applications (NF EN 81-71)<br>• Category 1 : Resistance tests following ch 5.3.1 | Compliant |

## 3 - SIGNATURE

First and last name : **Salvador JARA**
Function : **General Manager**

***Signature :***